



- NOTES:**
- CABLE TRAY SIZES FOR THE PANEL BOARDS AND TRAYS FROM THE MAINLINE SIZE OF CABLE OF THE EXPECTED LOAD WILL BE SUBMITTED LATER AFTER EQUIPMENT APPROVAL.
 - HOLE DIA FOR THE POWER SOCKET SHALL BE DRAWING + 3.0mm FOR ROUND/ROUNDS AS INDICATED IN THE DRAWING.
 - HEIGHT OF THE PANEL BOARDS (UNUSUAL) BE 1800mm TOP OF THE BOX FROM FINISH FLOORING AS PER APPROVED GENERAL NOTES & LEGEND DRAWING.
 - ALL DIM (GRID HEAD UNIT) GROUND APPEAR IN LIGHTING DRAWING.
 - ALL CCTV CIRCUIT SHOULD BE FEEDED FROM EMERGENCY PANEL.

- ELECTRICAL LEGEND:**
- PS: ISOLATED POWER SUPPLY
 - AL: ABOVE COUNTER
 - C: ABOVE CASE WORK
 - EM: EMERGENCY POWER SUPPLY
 - EP: ELECT. PANEL 3000/3000/3000
 - ES: ELECT. SLAB MAIN PANEL WITH 400V METER
 - 25mm PVC CONDUIT EMBEDDED IN FLOOR SLAB
 - NORMAL CIRCUIT
 - 25mm PVC CONDUIT EMBEDDED IN FLOOR SLAB
 - EMERGENCY CIRCUIT

TYP. THIRD & FORTH FLOOR PLAN POWER SOCKET
SCALE 1:200